

**AUTHORIZATION TO DISCHARGE UNDER THE
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM**

In compliance with the provisions of the Federal Clean Water Act as amended, (33 U.S.C. §§1251 *et seq.*; the "CWA"), and the Massachusetts Clean Waters Act, as amended, (M.G.L. Chap. 21, §§26-53),

**Town of Wayland
Wastewater Management District Commission
41 Cochituate Road
Wayland, MA 01778**

is authorized to discharge from the facility located at

**Town of Wayland Wastewater Treatment Plant
430/440 Boston Post Road
Wayland, MA 01778**

to receiving water named

Wetland adjacent to the Sudbury River (Concord River Watershed -MA 8247650)

in accordance with effluent limitations, monitoring requirements and other conditions set forth herein.

This permit shall become effective on the date of signature if no comments are received during the public notice period. If comments are received during the public notice period, this permit will become effective sixty days after signature.

This permit and the authorization to discharge expires at midnight, five (5) years from the effective date.

This permit supersedes the permit issued on September 4, 1998.

This permit consists of 14 pages in Part I including effluent limitations, monitoring requirements, Attachments A and B , and 35 pages in Part II including General Conditions and Definitions.

Signed this day of

Director
Office of Ecosystem Protection
Environmental Protection Agency
Boston, MA

Director
Division of Watershed Management
Department of Environmental Protection
Commonwealth of Massachusetts
Boston, MA

PART I

A1. During the period beginning the effective date and lasting until the outfall is extended to the Sudbury River or permit expiration, the permittee is authorized to discharge from outfall serial number 001, treated effluent to a wetland adjacent to the Sudbury River. Such discharges shall be limited and monitored as specified below. Effluent samples shall be taken after appropriate treatment and prior to discharge to Outfall 001. All sampling shall be representative of the effluent that is discharged through Outfall 001. A routine sampling program shall be developed in which samples are taken at the same location, same time and same day(s) of every month. Any deviations from the routine sampling program shall be documented in correspondence appended to the applicable discharge monitoring report that is submitted to EPA. Additionally, all samples shall be analyzed using the analytical methods found in 40 CFR 136, or alternative methods approved by EPA in accordance with the procedures in 40 CFR §136.

EFFLUENT LIMITS						MONITORING REQUIREMENTS	
PARAMETER	AVERAGE MONTHLY	AVERAGE WEEKLY	AVERAGE MONTHLY	AVERAGE WEEKLY	MAXIMUM DAILY	MEASUREMENT FREQUENCY	SAMPLE TYPE
FLOW	***	***	0.052 MGD ²	***	REPORT	CONTINUOUS	RECORDER ²
FLOW ²	***	***	Report (MGD)	***	REPORT	CONTINUOUS	RECORDER ²
BOD ₅ ⁴	13.0 lbs/Day 6.0 kgs/Day	20 lbs/Day 9 kgs/Day	30 mg/l	45 mg/l	REPORT	1/WEEK	24-HOUR COMPOSITE ^{3,5}
TSS ⁴	13.0 lbs/Day 6.0 kgs/Day	20 lbs/Day 9 kgs/Day	30 mg/l	45 mg/l	REPORT	1/WEEK	24-HOUR COMPOSITE ^{3,5}
pH RANGE ¹	6.5 - 8.3 SU SEE PERMIT PAGE 8 OF 14, PARAGRAPH I.A.1.b.						1/DAY GRAB ³
FECAL COLIFORM ^{1,6}	***	***	200 cfu/100 ml	***	400 cfu/100 ml	1/WEEK	GRAB ³
OIL & GREASE	***	***	REPORT	***	***	1/MONTH	GRAB ³
TOTAL PHOSPHORUS ^{1,3} (April 1 st - October 31 st)	***	***	0.2 mg/l	***	***	1/WEEK	24-HOUR COMPOSITE ^{3,5}
TOTAL PHOSPHORUS (November 1 st - March 31 st)	***	***	0.5 mg/l	***	***	1/WEEK	24-HOUR COMPOSITE ^{3,5}
ORTHO PHOSPHORUS (November 1 st - March 31 st)	***	***	Report mg/l	***	***	1/WEEK	24-HOUR COMPOSITE ^{3,5}
ALUMINUM ^{1,13}	***	***	87 ug/l	***	750 ug/l	1/MONTH	24-HOUR COMPOSITE ^{3,5}

A.1. During the period beginning the effective date and lasting through expiration, the permittee is authorized to discharge from outfall serial number **001**, treated effluent to a wetland adjacent to the Sudbury River. Such discharges shall be limited and monitored as specified below. Effluent samples shall be taken after appropriate treatment and prior to discharge to Outfall 001. All sampling shall be representative of the effluent that is discharged through Outfall 001. A routine sampling program shall be developed in which samples are taken at the same location, same time and same day(s) of every month. Any deviations from the routine sampling program shall be documented in correspondence appended to the applicable discharge monitoring report that is submitted to EPA. Additionally, all samples shall be analyzed using the analytical methods found in 40 CFR 136, or alternative methods approved by EPA in accordance with the procedures in 40 CFR §136.

EFFLUENT CHARACTERISTIC		EFFLUENT LIMITS				MONITORING REQUIREMENTS		
PARAMETER		AVERAGE MONTHLY	AVERAGE WEEKLY	AVERAGE MONTHLY	AVERAGE WEEKLY	MAXIMUM DAILY	MEASUREMENT FREQUENCY	SAMPLE TYPE
COPPER ¹³	***	***	9.2 ug/l	***	***	13.7 ug/l	1/MONTH	24-HOUR COMPOSITE ^{3,5}
LEAD ^{12, 13}	***	***	3.1 ug/l	***	***	79.6 ug/l	1/MONTH	24-HOUR COMPOSITE ^{3,5}
TOTAL AMMONIA, AS N	***	***	Report (mg/l)	***	Report (mg/l)	Report (mg/l)	1/WEEK	24-HOUR COMPOSITE ^{3,5}
WHOLE EFFLUENT TOXICITY					1/YEAR		24-HOUR COMPOSITE ^{3,5}	
Footnotes ^{7, 8, 9, 10}					Acute LC ₅₀ ≥ 100% Chronic C-NOEC ≥ 100%			

Footnotes:

1. Required for State Certification.
2. For flow, report maximum and minimum daily rates and total flow for each operating date. This is an annual average limit, which shall be reported as a rolling average. The first value will be calculated using the monthly average flow for the first full month ending after the effective date of the permit and the eleven previous monthly average flows. Each subsequent month's DMR will report the annual average flow for the previous 12 months.
3. Effluent samples shall be taken after appropriate treatment and prior to discharge to Outfall 001. All sampling shall be representative of the effluent that is discharged through Outfall 001 to the Sudbury River. A routine sampling program shall be developed in which samples are taken at the same location, same time and same day(s) of every month. Any deviations from the routine sampling program shall be documented in correspondence appended to the applicable discharge monitoring report that is submitted to EPA. In addition, all samples shall be analyzed using the analytical methods found in 40 CFR §136, or alternative methods approved by EPA in accordance with the procedures in 40 CFR §136.
4. Sampling required for influent and effluent.
5. A 24-hour composite sample will consist of at least twenty four (24) grab samples, which are flow proportional, and taken during a 24 hour cycle (e.g. 0700 Monday to 0700 Tuesday).
6. Fecal coliform limitations are in effect year round. This is a State certification requirement. Fecal coliform discharges shall not exceed a monthly geometric mean of 200 colony forming units (cfu) per 100 ml, nor shall they exceed 400 cfu per 100 ml as a daily maximum.
7. The permittee will conduct 7-day chronic (and modified acute) toxicity tests four times per year, and will test the daphnid, *Ceriodaphnia dubia*. Toxicity test samples will be collected during the second week in March, June, September and December. The test results will be submitted by the last day of the month following the completion of the test. The results are due April 30th, July 31st, October 31st, and January 31st, respectively. The tests must be performed in accordance with test procedures and protocols specified in **Attachment A** of this permit.

Test Date Second Week in	Submit Results By:	Test Species	Acute Limit LC_{50}^8	Chronic Limit C- NOEC ⁹
March	April 30 th	<i>Ceriodaphnia dubia</i>	≥ 100%	≥ 100%
June	July 31 st			
September	October 31 st	See Attachment A		
December	January 31 st			

After submitting four consecutive sets of whole effluent toxicity (WET) test results, all of which

demonstrate compliance with the WET permit limits, the permittee may request a reduction in the WET testing requirements. The permittee is required to continue testing in accordance with the

permit until notice is received by certified mail from the EPA that the WET testing requirements have been changed.

8. The LC₅₀ is the concentration of effluent which causes mortality to 50% of the test organisms. Therefore, a 100% limit means that a sample of 100% effluent (no dilution) shall cause no more than a 50% mortality rate.
9. C-NOEC (chronic-no observed effect concentration) is defined as the highest concentration of toxicant or effluent to which organisms are exposed in a life cycle or partial life cycle test which causes no adverse effect on growth, survival, or reproduction at a specific time of observation as determined from hypothesis testing where the test results exhibit a linear dose-response relationship. However, where the test results do not exhibit a linear dose-response relationship, the permittee must report the lowest concentration where there is no observable effect. The "100% or greater" limit is defined as a sample which is composed of 100% effluent. This is a maximum daily limit derived as a percentage of the inverse of the dilution factor of 1.
10. If toxicity test(s) using receiving water as diluent show the receiving water to be toxic or unreliable, the permittee shall follow procedures outlined in **Attachment A Section IV., DILUTION WATER** in order to obtain permission to use an alternate dilution water. In lieu of individual approvals for alternate dilution water required **in Attachment A**, EPA-New England has developed a Self-Implementing Alternative Dilution Water Guidance document (called "Guidance Document") which may be used to obtain automatic approval of an alternate dilution water, including the appropriate species for use with that water. If this Guidance document is revoked, the permittee shall revert to obtaining approval as outlined in **Attachment A**. The "Guidance Document" has been sent to all permittees with their annual set of DMRs and Revised Updated Instructions for Completing EPA's Pre-Printed NPDES Discharge Monitoring Report (DMR) Form 3320-1 and is not intended as a direct attachment to this permit. Any modification or revocation to this "Guidance Document" will be transmitted to the permittees as part of the annual DMR instruction package. However, at any time, the permittee may choose to contact EPA-New England directly using the approach outlined in **Attachment A**.
11. Aluminum sampling shall be conducted concurrently with phosphorus sampling.
12. The minimum level (ML) for lead is defined as 3 ug/l. This value is the minimum level for lead using the Furnace Atomic Absorption analytical method (EPA Method 220.2). This method must be used to determine total lead. For effluent limitations less than 3 ug/l, compliance/non-compliance will be determined based on the ML. Sample results of 3 ug/l or less shall be reported as zero on the Discharge Monitoring Report.
13. The Permittee shall comply with the limits in accordance with the compliance schedule appearing in Section F. During the interim, a limit of 0.5 mg/l total phosphorus shall apply with monitoring once per week (1/Week) and there shall be no effluent limitations for aluminum, copper and lead, which shall be monitored once per month (1/Month) using 24 hour composite samples. These interim requirements are in effect until the actions required by the compliance schedule are completed.

A.2.** During the period beginning with the completion of the outfall relocation to the Sudbury River, and lasting through expiration, the permittee is authorized to discharge from outfall serial number **001**, treated effluent to the Sudbury River. Such discharges shall be limited and monitored as specified below. Effluent samples shall be taken after appropriate treatment and prior to discharge to Outfall 001. All sampling shall be representative of the effluent that is discharged through Outfall 001. A routine sampling program shall be developed in which samples are taken at the same location, same time and same day(s) of every month. Any deviations from the routine sampling program shall be documented in correspondence appended to the applicable discharge monitoring report that is submitted to EPA. Additionally, all samples shall be analyzed using the analytical methods found in 40 CFR 136, or alternative methods approved by EPA in accordance with the procedures in 40 CFR §136.

EFFLUENT CHARACTERISTIC		EFFLUENT LIMITS				MONITORING REQUIREMENTS		
PARAMETER		AVERAGE MONTHLY	AVERAGE WEEKLY	AVERAGE MONTHLY	AVERAGE WEEKLY	MAXIMUM DAILY	MEASUREMENT FREQUENCY	SAMPLE TYPE
FLOW	***	***	0.052 MGD ²	***	***	REPORT	CONTINUOUS	RECORDER ²
FLOW ²	***	***	Report (MGD)	***	***	REPORT	CONTINUOUS	RECORDER ²
BOD ₅ ⁴	13.0 lbs/Day 6.0 kgs/Day	20 lbs/Day 9 kgs/Day	30 mg/l	45mg/l	45mg/l	REPORT	1/WEEK	24-HOUR COMPOSITE ^{3,5}
TSS ⁴	13.0 lbs/Day 6.0 kgs/Day	20 lbs/Day 9 kgs/Day	30 mg/l	45 mg/l	45 mg/l	REPORT	1/WEEK	24-HOUR COMPOSITE ^{3,5}
pH RANGE ¹	6.5 - 8.3 SU SEE PERMIT PAGE 8 OF 14, PARAGRAPH I.A.1.b.				1/DAY	GRAB ³		
FECAL COLIFORM ^{1,6}	***	***	200 cfu/100 ml	***	400 cfu/100 ml	1/WEEK	GRAB ³	
OIL & GREASE	***	***	Report	***	***	1/MONTH	GRAB ³	
TOTAL PHOSPHORUS (April 1 st - October 31 st)	***	***	0.2 mg/l	***	***	1/WEEK	24-HOUR COMPOSITE ^{3,5}	
TOTAL PHOSPHORUS (November 1 st - March 31 st)	***	***	0.5 mg/l	***	***	1/WEEK	24-HOUR COMPOSITE ^{3,5}	

*The Permittee shall notify both EPA and DEP 60 days prior commencing discharge to the Sudbury River. The limits found on Pages 4-5

this permit shall apply beginning with the first full calendar month after commencing discharge to the Sudbury River.

A.2.** During the period beginning with the completion of the outfall relocation to the Sudbury River, and lasting through expiration, the permittee is authorized to discharge from outfall serial number **001**, treated effluent to the Sudbury River. Such discharges shall be limited and monitored as specified below. Effluent samples shall be taken after appropriate treatment and prior to discharge to Outfall 001. All sampling shall be representative of the effluent that is discharged through Outfall 001. A routine sampling program shall be developed in which samples are taken at the same location, same time and same day(s) of every month. Any deviations from the routine sampling program shall be documented in correspondence appended to the applicable discharge monitoring report that is submitted to EPA. Additionally, all samples shall be analyzed using the analytical methods found in 40 CFR 136, or alternative methods approved by EPA in accordance with the procedures in 40 CFR §136.

EFFLUENT LIMITS						MONITORING REQUIREMENTS	
PARAMETER	AVERAGE MONTHLY	AVERAGE WEEKLY	AVERAGE MONTHLY	AVERAGE WEEKLY	MAXIMUM DAILY	MEASUREMENT FREQUENCY	SAMPLE TYPE
ORTHO PHOSPHORUS (November 1 st - March 31 st)	***	***	Report mg/l	***	***	1/WEEK	24-HOUR COMPOSITE ^{3,5}
TOTAL AMMONIA, AS N	***	***	Report (mg/l)	***	Report (mg/l)	1/WEEK	24-HOUR COMPOSITE ^{3,5}
ALUMINUM ¹¹	***	***	***	***	***	1/MONTH	24-HOUR COMPOSITE ^{3,5}
WHOLE EFFLUENT TOXICITY Footnotes 7,8, 10	Acute LC ₅₀ ≥ 100%					1/YEAR	24-HOUR COMPOSITE ^{3,5}

****The Permittee shall notify both EPA and DEP 60 days prior commencing discharge to the Sudbury River. The limits found on Pages 4-5 this permit shall apply beginning with the first full calendar month after commencing discharge to the Sudbury River.**

Footnotes:

1. Required for State Certification.
2. For flow, report maximum and minimum daily rates and total flow for each operating date. This is an annual average limit, which shall be reported as a rolling average. The first value will be calculated using the monthly average flow for the first full month ending after the effective date of the permit and the eleven previous monthly average flows. Each subsequent month's DMR will report the annual average flow for the previous 12 months.
3. Effluent samples shall be taken after appropriate treatment and prior to discharge to Outfall 001. All sampling shall be representative of the effluent that is discharged through Outfall 001 to the Sudbury River. A routine sampling program shall be developed in which samples are taken at the same location, same time and same day(s) of every month. Any deviations from the routine sampling program shall be documented in correspondence appended to the applicable discharge monitoring report that is submitted to EPA. In addition, all samples shall be analyzed using the analytical methods found in 40 CFR §136, or alternative methods approved by EPA in accordance with the procedures in 40 CFR §136.
4. Sampling required for influent and effluent.
5. A 24-hour composite sample will consist of at least twenty four (24) grab samples, which are flow proportional, and taken during a 24 hour cycle (e.g. 0700 Monday to 0700 Tuesday).
6. Fecal coliform limitations are in effect year round. This is a State certification requirement. Fecal coliform discharges shall not exceed a monthly geometric mean of 200 colony forming units (cfu) per 100 ml, nor shall they exceed 400 cfu per 100 ml as a daily maximum.
7. The permittee shall conduct acute WET testing for the Outfall 001 effluent once per year using *Ceriodaphnia dubia* and *Pimphales promelas*. Toxicity test samples shall be collected during the second week of August, and the results shall be submitted by September 30th. The test must be performed in accordance with test procedures and protocols specified in **Attachment A** of this permit.

Test Date Second Week in	Submit Results By:	Test Species	Acute Limit LC_{50}^8
September	October 31 st	<i>Ceriodaphnia dubia</i> <i>Pimphales promelas</i> See Attachment A	$\geq 100\%$

8. The LC₅₀ is the concentration of effluent which causes mortality to 50% of the test organisms. Therefore, a 100% limit means that a sample of 100% effluent (no dilution) shall cause no more than a 50% mortality rate.
9. C-NOEC (chronic-no observed effect concentration) is defined as the highest concentration of toxicant or effluent to which organisms are exposed in a life cycle or partial life cycle test which causes no adverse effect on growth, survival, or reproduction at a specific time of observation as determined from hypothesis testing where the test results exhibit a linear dose-response relationship. However, where the test results do not exhibit a linear dose-response relationship, the permittee must report the lowest concentration where there is no observable effect. The "100% or greater" limit is defined as a sample which is composed of 100% effluent. This is a maximum daily limit derived as a percentage of the inverse of the dilution factor of 1.
10. If toxicity test(s) using receiving water as diluent show the receiving water to be toxic or unreliable, the permittee shall follow procedures outlined in **Attachment A Section IV., DILUTION WATER** in order to obtain permission to use an alternate dilution water. In lieu of individual approvals for alternate dilution water required **in Attachment A**, EPA-New England has developed a Self-Implementing Alternative Dilution Water Guidance document (called "Guidance Document") which may be used to obtain automatic approval of an alternate dilution water, including the appropriate species for use with that water. If this Guidance document is revoked, the permittee shall revert to obtaining approval as outlined in **Attachment A**. The "Guidance Document" has been sent to all permittees with their annual set of DMRs and Revised Updated Instructions for Completing EPA's Pre-Printed NPDES Discharge Monitoring Report (DMR) Form 3320-1 and is not intended as a direct attachment to this permit. Any modification or revocation to this "Guidance Document" will be transmitted to the permittees as part of the annual DMR instruction package. However, at any time, the permittee may choose to contact EPA-New England directly using the approach outlined in **Attachment A**.
11. Aluminum sampling shall be conducted concurrently with phosphorus sampling.

Part IA.1. (Continued)

- a. The discharge shall not cause an excursion of the water quality standards of the receiving waters.
- b. The pH of the effluent shall not be less than 6.5 nor greater than 8.3 at any time.
- c. The discharge shall not cause objectionable discoloration of the receiving waters.
- d. The effluent shall contain neither a visible oil sheen, foam, nor floating solids at any time.
- e. The permittee's treatment facility shall maintain a minimum of 85 percent removal of both total suspended solids and biochemical oxygen demand. The percent removal shall be based on monthly average values.
- f. The results of sampling for any parameter above its required frequency must also be reported.

2. The permittee must provide adequate notice to the Director of the following:

- a. Any new introduction of pollutants into the POTW from an indirect discharger in a primary industry category discharging process water; and
- b. Any substantial change in the volume or character of pollutants being introduced into the POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
- c. For purposes of this paragraph, adequate notice shall include information on:
 - (1) the quantity and quality of effluent introduced into the POTW; and
 - (2) any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

3. Prohibitions Concerning Interference and Pass-Through:

- a. Pollutants introduced into the POTW by a non-domestic source (user) shall not pass through the POTW or interfere with the operation or performance of the works.

4. Toxics Control

- a. The permittee shall not discharge any pollutant or combination of pollutants in toxic amounts.
- b. Any toxic components of the effluent shall not result in any demonstrable harm to aquatic life or violate any state or federal water quality standard which has been or may be promulgated. Upon promulgation of any such standard, this permit may be revised or amended in accordance with such standards.

5. Numerical Effluent Limitations for Toxicants

EPA or MassDEP may use the results of the toxicity tests and chemical analyses conducted pursuant to this permit, as well as national water quality criteria developed pursuant to Section 304(a)(1) of the Clean Water Act (CWA), state water quality criteria, and any other appropriate information or data, to develop numerical effluent limitations for any pollutants, including but not limited to those pollutants listed in Appendix D of 40 CFR Part 122.

B. UNAUTHORIZED DISCHARGES

The permittee is authorized to discharge only in accordance with the terms and conditions of this permit and only from the outfall listed in Part I A.1. and A.2. of this permit. Discharges of wastewater from any other

point sources, including sanitary sewer overflows (SSOs) are not authorized by this permit and shall be reported in accordance with Section D.1.e. (1) of the General Requirements of this permit (Twenty-four hour reporting).

C. INFILTRATION/INFLOW

The permittee shall control infiltration and inflow (I/I) to the separate sewer system to prevent infiltration/inflow-related effluent limit violations, and any unauthorized discharges of wastewater, including overflows and by-passes, due to excessive infiltration/inflow.

D. OPERATION AND MAINTENANCE OF THE SEWER SYSTEM

Operation and maintenance of the sewer system shall be in compliance with the General Requirements of Part II and the following terms and conditions:

1. Maintenance Staff

The permittee shall provide an adequate staff to carry out the operation, maintenance, repair, and testing functions required to ensure compliance with the terms and conditions of this permit.

2. Preventative Maintenance Program

The permittee shall maintain an ongoing preventative maintenance program to prevent overflows and bypasses caused by malfunctions or failures of the sewer system infrastructure. The program shall include an inspection program designed to identify all potential and actual unauthorized discharges.

3. Alternate Power Source

In order to maintain compliance with the terms and conditions of this permit, the permittee shall provide an alternative power source with which to sufficiently operate its treatment works (as defined at 40 CFR §122.2).

E. SLUDGE CONDITIONS

1. The permittee shall comply with all existing federal and state laws and regulations that apply to sewage sludge use and disposal practices and with the CWA Section 405(d) technical standards.
2. The permittee shall comply with the more stringent of either the state or federal (40 CFR part 503), requirements.
3. The requirements and technical standards of 40 CFR part 503 apply to facilities which perform one or more of the following use or disposal practices.
 - a. Land application - the use of sewage sludge to condition or fertilize the soil
 - b. Surface disposal - the placement of sewage sludge in a sludge only landfill
 - c. Sewage sludge incineration in a sludge only incinerator
4. The 40 CFR part 503 conditions do not apply to facilities which place sludge within a municipal solid

waste landfill. These conditions also do not apply to facilities which do not dispose of sewage sludge during the life of the permit but rather treat the sludge (e.g. lagoons- reed beds), or are otherwise excluded under 40 CFR 503.6.

5. The permittee shall use and comply with the attached compliance guidance document to determine appropriate conditions. Appropriate conditions contain the following elements.

- General requirements
- Pollutant limitations
- Operational Standards (pathogen reduction requirements and vector attraction reduction requirements)
- Management practices
- Record keeping
- Monitoring
- Reporting

Depending upon the quality of material produced by a facility, all conditions may not apply to the facility.

6. The permittee shall monitor the pollutant concentrations, pathogen reduction and vector attraction reduction at the following frequency. This frequency is based upon the volume of sewage sludge generated at the facility in dry metric tons per year:

less than 290	1/ year
290 to less than 1500	1 /quarter
1500 to less than 15000	6 /year
15000 +	1 /month

7. The permittee shall sample the sewage sludge using the procedures detailed in 40 CFR 503.8.
8. The permittee shall submit an annual report containing the information specified in the guidance by **February 19**. Reports shall be submitted to the address contained in the reporting section of the permit. Sludge monitoring is not required by the permittee when the permittee is not responsible for the ultimate sludge disposal. The permittee must be assured that any third party contractor is in compliance with appropriate regulatory requirements. In such case, the permittee is required only to submit an annual report by **February 19** containing the following information:
 - Name and address of contractor responsible for sludge disposal
 - Quantity of sludge in dry metric tons removed from the facility by the sludge contractor

F. COMPLIANCE SCHEDULE

In order to comply with the permit limits for total phosphorus, copper, lead and aluminum, the Permittee shall take the following actions:

1. Within twelve (12) months of the effective date of the permit, the Permittee shall evaluate and select an options for;

- a) extending the outfall to the Sudbury River, and/or
b) upgrading the Wayland WWTF, including, but not limited to, evaluating groundwater discharge and water conservation measures.

2. Within twelve (12) months of completing this evaluation, the Permittee shall complete the design for the selected option(s).
3. Within two (2) years of completing the design, the Permittee shall complete construction of the selected option(s).

G. MONITORING AND REPORTING

1. Reporting

Monitoring results obtained during each calendar month shall be summarized and reported on Discharge Monitoring Report Form(s) postmarked no later than the 15th day of the following month.

Signed and dated originals of these, and all other reports required herein, shall be submitted to the Director and the State at the following addresses:

Environmental Protection Agency
Water Technical Unit (SEW)
P.O. Box 8127
Boston, Massachusetts 02114

The State Agency is:

Massachusetts Department of Environmental Protection
Northeast Regional Office- Bureau of Resource Protection
205b Lowell Street
Wilmington, Massachusetts 01887

Signed and dated Discharge Monitoring Report Forms and toxicity test reports required by this permit shall also be submitted to the State at:

Massachusetts Department of Environmental Protection
Division of Watershed Management
Surface Water Discharge Permit Program
627 Main Street, 2nd Floor
Worcester, Massachusetts 01608

H. STATE PERMIT CONDITIONS

This Discharge Permit is issued jointly by the U. S. Environmental Protection Agency (EPA) and the Massachusetts Department of Environmental Protection (MassDEP) under Federal and State law, respectively. As such, all the terms and conditions of this permit are hereby incorporated into and constitute a discharge permit issued by the Commissioner of the MassDEP pursuant to M.G.L. Chap. 21, §43.

Each Agency shall have the independent right to enforce the terms and conditions of this permit. Any modification, suspension or revocation of this Permit shall be effective only with respect to the Agency taking such action, and shall not affect the validity or status of this permit as issued by the other Agency, unless and until each Agency has concurred in writing with such modification, suspension or revocation. In the event any portion of this Permit is declared, invalid, illegal or otherwise issued in violation of State law such permit shall remain in full force and effect under Federal law as an NPDES Permit issued by the U.S. Environmental Protection Agency. In the event this Permit is declared invalid, illegal or otherwise issued in violation of Federal law, this Permit shall remain in full force and effect under State law as a Permit issued by the Commonwealth of Massachusetts.